

**CLEVELAND COUNTY WATER
FIRE SPRINKLER SYSTEM
SPECIFICATION**



**ALL FITTINGS ARE REQUIRED TO HAVE
RESTRAINED JOINT FITTINGS.**

