

The Water We Drink

The City of Kings Mountain, N.C.
PWSID # NC 01-23-020

MARCH 11, 2021

Following is the Annual Water Quality Report for 2020. Our goal is to provide to you a safe and dependable supply of drinking water. Our water source is Moss Lake on the Clear Fork of Buffalo Creek. Moss Lake is a surface water source. The water supply for the City of Kings Mountain is sufficient for many years, and is of excellent quality. In our continuing efforts to maintain a safe and dependable water supply it will, from time to time, be necessary to make improvements in your water system. Costs of these improvements may be reflected in future rate structures.

If you have any questions about this report or concerning your water utility, please contact Newt Henson, Jr. at 704- 482-7131 from 7:00AM until 3:00PM weekdays. We want our valued customers to be informed. If you want to learn more, please attend any of our regularly scheduled City Council meetings. They are held on the last Tuesday of each month at the Kings Mountain City Hall Council Chambers at 6:00 PM.

Kings Mountain monitors for more than 160 contaminants in our drinking water according to Federal and State laws. This table shows the results of our monitoring for the period of January 1st to December 31st, 2020. The EPA and the State allow us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year.

What EPA Wants You to Know

Some people are more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have had organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead: If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The City of Kings Mountain is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and steps you can take to minimize

exposure is available from the Safe Drinking Water Hotline, or at <http://www.epa.gov/safewater/lead>.

All drinking water, including bottled water, may be expected to contain at least small amounts of contaminants. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. It is important to remember that the presence of these contaminants does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 1-800-426-4791.

In this report you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms we've provided the following definitions:

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Maximum Contaminant Level The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal the "Goal" (MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

What does all this mean?

We're proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels. MCL's are set at very stringent levels. To help you understand the possible health effects described for many regulated constituents, a person would have to drink 1/2 gallon of water every day, at the MCL level, for a lifetime to have a one-in-a-million chance of having the described health effect.

We of the City of Kings Mountain water system work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.

The City of Kings Mountain

Consumer Confidence Report



Microbiological Contaminants Sampled Daily In 2020

Contaminant (units)	MCL Violation Y/N	Your Water Samples	MCL G	MCL	Likely Source of Contamination
Total Coliforms (Bacteria presence or absence)	N	0	0	one monthly positive	Naturally present in the environment.
Fecal Coliform (presence or absence)	N	0	0	a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E. coli positive	Human and animal fecal waste

Turbidity - Continuous Monitoring In 2020

Contaminant (units)	MCL Violation Y/N	Your Water (gallons)	MCLG	MCL	Likely Source of Contamination
Turbidity (NTU) AVG-0.081	N	0.366	N/A	TT = 5 NTU	Soil runoff

* Turbidity is a measure of the cloudiness of the water. We monitor it because it is a good indicator of the effectiveness of our filtration system. The turbidity rule requires that 98% or more of the monthly samples must be below 0.5 NTU.

Inorganics - Sampled Daily In 2020

Inorganic Chemical	Sample Date	MCL Violation Y/N	Your Water	Range Low/High	MCL	Likely Source of Contamination
Fluoride (ppm)	2/20/20	N	0.70 AVG.	0.50-1.00	4	Emission of natural deposits, fertilizers, herbicides, pesticides, and other additives which permeate strong acids, strong bases, and other chemicals from fertilizers and aluminum electrolysis

PEST/SOC Annual Sample 2020

Contaminant (units)	Sample Date	Your Water	Range Low/High	MCL	Likely Source of Contamination
25 Contaminants tested for	7/14/20	ND	0.00-0.00	0.00	Runoff or leaching from Agricultural and Industrial users.
1 Contaminant Detected: Atrazine	7/14/20	0.0004	Allowable Limit 0.05 mg/l		Herbicide on crops, lawns and golf courses.
4 quarts of sampling started 12/16/20 for Atrazine	12/16/20	ND			

Lead and Copper Contaminants Sampled During September 2019

Contaminant (units)	Sample Date	Your Water	Range Low/High	MCL	Likely Source of Contamination
Copper (ppm) (90% percentiles)	9/20/16	<0.059	0	1.3	Corrosion of household plumbing systems; erosion of natural deposits, leaching from wood preservatives
Lead (ppb) (90% percentiles)	9/20/16	<0.003	0	0	Corrosion of household plumbing systems; erosion of natural deposits

Next Lead and Copper Monitoring will be in September 2022

Disinfection By-Product Precursors Contaminants - Sampled Monthly 2020

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water Avg.	Range Low/High	MCL	Likely Source of Contamination
Total Organic Carbon (ppm) (TOC)-BAW	2/20/20	N	3.0	2.7-3.5	5	Naturally present in the environment
Total Organic Carbon (ppm) (TOC)-TREATED	2/20/20	N	1.4	1.2-1.7	5	Naturally present in the environment

Note: Depending on the TOC in our source water, the system MUST have a certain % removal of TOC or must achieve alternative compliance techniques. If we do not achieve that % removal, there is an alternative removal. If we fail to meet that, we are in violation of a Treatment Technique.

Other Analysis In 2020

Sodium	10.2 ppm	MCL - 20 ppm
Volatile Organic Chemicals (VOCs)	No Detection of 21 VOC Contaminants	MCL varies dependent on contaminant

Contaminant	Sample Date	MCL Violation Y/N	Your Water	Range Low/High	MCL	Likely Source of Contamination
Iron (ppm)	2/20/20	N	.002	.001-.015	0.30	Naturally present in the environment
Manganese (ppm)	2/20/20	N	.007	.001-.032	0.05	Naturally present in the environment
pH			7.9		Low 7.4 High 8.5	

Asbestos Contaminant In 2020

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low/High	MCL	Likely Source of Contamination
Total Asbestos or (PCL)	7/14/20	N	<0.20	N/A	7	Due to asbestos cement water main, erosion of natural deposits

Next monitoring period is in 2025

Radionuclide Contaminants - Sampled In 2015

Contaminant (units)	Sample Date	MCL Violation Y/N	Your Water	Range Low/High	MCL	Likely Source of Contamination
Alpha emitters (GCI)	2/18/15	N	ND	0	15	Erosion of natural deposits
Beta emitters (GCI)	2/18/15	N	ND	0	2	Density of natural and man-made deposits
Beta emitters (GCI)	2/18/15	N	ND	0	3	Erosion of natural deposits
Uranium (GCI)	2/18/15	N	ND	0	20.1	Erosion of natural deposits

Next monitoring period is in 2024

UCMR - Unregulated Contaminant Monitoring Rule.

December 2020 concluded our monitoring of UCMR Phase 4

No detections were found.

Disinfection By-Products, Sampled In 2020

Note: Chlorine Continuously Monitored. Disinfection By Products sampled quarterly.

Contaminant (units)	MCL Violation Y/N	Your Water (AVG)	Range Low/High	MCLG	MCL	Likely Source of Contamination
THM4 (ppb) (Trihalomethanes)	N	45	29-55	N/A	80	By-product of drinking water chlorination
HAAs (ppb) (Haloacetic Acids)	N	27	24-32	N/A	60	By-product of drinking water disinfection
Chlorine (ppm)	N	1.18	0.57-1.67	MREDG = 4	MREDL = 4	Water additive used to control microbes

Cryptosporidium: 2017

Our system began monitoring in October 2016 and monitored monthly for 24 consecutive months.

No detection of cryptosporidium was found in our monthly water samples during 2016 - 2017 period.

SOURCE WATER ASSESSMENT PROGRAM (SWAP)

RESULTS: The North Carolina Department of Environment and Natural Resources, Public Water Supply Section conducted assessments for all drinking water sources in North Carolina. The purpose of these assessments are to determine the susceptibility of each drinking water source for potential contaminants sources (PCS's) It is important to understand that the susceptibility rating does not mean poor water quality, only the potential to become contaminated by sources in the assessment area.

SOURCE NAME: JOHN H MOSS LAKE. Report Date 2/19/10
SUSCEPTIBILITY RATING: MODERATE

The complete SWAP Report may be viewed at <http://www.deh.enr.state.nc.us/pws/swap>. To obtain a printed copy, mail a written request to WATER ASSESSMENT PROGRAM-REPORT REQUEST, 1634 MAIL SERVICE CENTER, RALEIGH, NC 27699-1634 or E-mail request to swap@ncdenr.gov. Please include your water system name, PWSID and your name, address and phone number with your request. You may also call 919-707-9098 with any questions.